

Fire Department • Fire and Environmental Protection Division • 1000 Villa Street • Mountain View, CA 94041-1295
650-903-6378 • FAX 650-903-6122

**6-MONTH FIXED FIRE PROTECTION SYSTEM
SERVICE TEST REPORT
(Updated 5/21/03)**

NFPA 25 and the Uniform Fire Code requires fixed (engineered) fire protection systems to be inspected and service tested at least every 6 months. Fixed (engineered) fire protection systems include, but are not limited to:

- spray-paint booth fire extinguishing systems,
- computer room halon (or halon replacement) extinguishing systems,
- kitchen hood and duct fire extinguishing systems,
- chemical storage shed chemical extinguishing systems, etc.

In Mountain View, a record of the inspection and test, along with any deficiencies found, shall be submitted to the Mountain View Fire Department. The test shall only be conducted by a licensed contractor familiar with the system. While test procedures will vary according to the system, the information outlined below should be included with every test submittal.

Business Name : _____

Site Location (address): _____

System Description: _____

Testing Contractor: _____ License #: _____

Testing Contractor Address: _____ Phone: _____

Certification Date: _____

☐ Attach copy of service test results from contractor.

LIST DEFICIENCIES FOUND AND HOW/WHEN CORRECTED

<p><i>Return completed form to:</i> City of Mountain View Fire Department 1000 Villa Street Mountain View, CA 94041 Attn: Fire Marshal</p>
--

